

INSTRUCTION
FIRE SAFETY DURING ASSEMBLING (DISASSEMBLING) OF EXHIBIT DISPLAYS
AND RUNNING OF EXHIBITION EVENTS IN INDOOR AND OUTDOOR AREAS OF
CROCUS EXPO KRASNOGORSK SUBSIDIARY JSC CROCUS

I. GENERAL PROVISIONS

1. The present Instruction has been created on the grounds of the Federal law No. 69-FZ “Concerning Fire Safety” dated December 21, 1994, the Federal law No. 123-FZ “Technical regulations for fire safety requirements” dated July 22, 2008 and in accordance with the Fire Regulations in the Russian Federation approved by the Regulation of the government of the Russian Federation No. 390 dated 25.04.2012, General instruction on fire safety measures in the JSC CROCUS approved by the Order of General Director of JSC CROCUS, Essential requirements applicable when holding events in the Crocus Expo International Exhibition Center approved by Director of Crocus Expo Krasnogorsk Subsidiary JSC CROCUS.

Instruction sets the main directions of fireproofing in exhibition halls of pavilions, outdoor areas of Crocus Expo IEC in accordance with the requirements of GOST 12.1.004-91 "Fire Safety. General requirements", the fire safety regulations, building codes and regulations, as well as procedures to ensure safety of people and wealth, creating conditions for effective fire extinguishing and is mandatory for all employees of the Crocus Expo IEC, staff of tenant enterprises, enterprises who are the organizers, developers and participants, other persons present in the pavilions.

2. The responsibility for the fire safety of exhibition halls entrusts with the Deputy Chief Engineer of Crocus Expo IEC.

3. The responsibility for compliance with fire safety conditions during assembling (disassembling) equipment exhibition stands (expositions), holding of exhibitions and other events within the authorized leaders (representatives) event organizers, builders, developers and participants of the event on the leased area.

Control over compliance with fire safety conditions during installation (dismantling), an exhibition and other activities carried out by authorized officers of the fire department (Fire Department) JSC CROCUS and senior officials Department of the exhibitions, Department of the arrangement of exhibitions, Department of non-exhibit and congress events, Department of special exhibitions of Crocus Expo IEC and representatives of General Builder in Crocus Expo IEC.

4. Officials who responsible for compliance with fire safety conditions are required be trained in fire-technical program in a minimum of specialized organizations (training center) , a licensed Russian Ministry for Emergency Situations for the training in fire safety measures, and have a certificate of training completion;

The officials of the entities engaged in the arrangement of events with mass presence of people, liable for securing the fire safety:

– Shall get a fire prevention briefing at the Fire Department of JSC CROCUS regarding the control and compliance with the fire safety and safe evacuation of people (visitors and exhibitors) in case of emergency situations and breaking of fire;

– To ensure the designation of a mobile fire post (fire team based on a fire fighting vehicle) when the area of development of the exhibit event equals 10,000 sqm and more;

– Ensure compliance with the basic requirements for construction of the exhibition space and installation of exhibits, coordination of project documentation, letters on materials for construction and design of stands, fire safety rules, smoking regime in the areas of work and the development area of the exhibition stand (exposure);

– Detection of faults in the network engineering and temporary engineering facilities, which could lead to fire (ignition), shall take immediate action to stop the operation of networks, facilities and equipment, calling for qualified specialists of Crocus Expo IEC and representatives of General Builder to eliminate the failures;

– To organize and supervise the cleaning work areas and exposures off lighting power, electrical load, computer and copying equipment at the end of work;

– Ensure the safety of existing (rented) primary fire extinguishing equipment, firefighting equipment, communication and fire alarm systems as well as maintenance of escape routes, main and emergency exits;

- Use primary fire extinguishing equipment, fire equipment for domestic and other purposes not related to fire fighting is forbidden;
- Prior to removal of exhibits to pass the equipment rented extinguishing agents;
- Timely implementation of all fire protection measures proposed by authorized personnel of FD JSC CROCUS.

5. Builders of exhibition stands (expositions), the participants of exhibitions and other activities required to know and comply with the established fire support mode in the exhibition halls, pavilions and areas to avoid actions that lead to fire.

6. Organizers, developers, exhibitors guilty of violating fire safety conditions, depending on the nature of the violations and their consequences are responsible in accordance with applicable labor, administrative, criminal and civil legislation of the Russian Federation. (Appendix 1)

All matters not covered by this instruction and occurred during the erection and dismantling of the event, settled on the spot by event organizers, responsible directors, the Deputy Chief Engineer of Crocus Expo IEC, representatives of General Builder and the authorized representatives of the FD JSC CROCUS.

II. PROCEDURES FOR MAINTENANCE PAVILION AREAS

7. The area around the building pavilions, exhibition halls of Crocus Expo IEC must be kept clean and regularly cleaned of debris and combustible waste containers. Combustible waste, oily cotton waste and disposable containers stored outside the building of the pavilion, in a specially designated and equipped location in fireproof containers and no closer than 10 m to the buildings. Fires, burning of waste and packing adjacent to the pavilion area of 50 m forbidden.

Storage of building materials, structures, equipment and property within the space during installation (dismantling) and the event is only allowed within the exhibition area transferred under construction. Cluttering the aisles between the stands is not allowed.

Storage, even temporary, combustible waste and packaging machinery exhibition halls is prohibited. Unneeded transportation boxes, containers and their equipment must be removed from the exhibition halls or storage should be organized in a warehouse (tare stock) at the designated location (site).

Storage building and other materials, exhibition equipment, containers, storage of containers of highly flammable liquids (HFL) and combustible (C), bulbs with combustion gases (CG) close to the outer walls of buildings and pavilions for transitions between the pavilions are not allowed. Storage areas are coordinated with FD JSC CROCUS and should be located no closer than 10 meters from the exterior walls of pavilions.

Temporary structures (tents, booths, tents, pavilions, containers, exposure, etc.) should be placed on buildings and structures pavilions at least 15 m.

8. Smoking in the exhibition halls in the area (location) exposure is strictly prohibited. Smoking is allowed only in specially designated and equipped for this purpose located not closer than 15 meters from entrances to buildings and pavilions.

9. Roads, driveways and entrances to buildings and facilities of pavilions of Crocus Expo IEC, outdoor fire emergency (evacuation) stairways, fire hydrants must be kept clear for the passage of firefighting equipment, in working order and in winter to be cleared of snow and ice. Parking of vehicles on fire hydrant manhole covers and within 2 m from them is prohibited.

10. In operation, evacuation routes and exits shall be prohibited:

- Block evacuation routes and exits (aisles, corridors, lobbies, galleries, lift lobbies, landings, flight of stairs, doors, escape hatches, etc.), approaches to the cabinets fire hydrants fighting primary means, alarm and electric boards, exhibition stands (exposures), advertising posters, boards and information bars, a variety of materials, goods, equipment, debris, and other objects, as well as the score, close the door locks on emergency exits;
- Arrange in vestibules of main and emergency exits dryer and clothes hangers, wardrobes, as well as store, including temporarily, equipment and materials;
- Fix closing doors staircases, corridors, halls and vestibules in the open position, as well as remove them.

11. Every day at the end of the exhibition exposition, exhibition stands should be inspected by officials responsible for fire safety. Expositions may be closed only after cleaning, removal of

debris, packaging and packaging waste, disconnect electrical appliances, office equipment and lighting.

III. ARRANGEMENTS FOR FIRE SAFETY DURING INSTALLATION EXPOSITIONS AND RUNNING EXHIBITION EVENTS

12. Organizers of exhibition and other events with mass people stay no later than ten (10) calendar days prior to the Overall Event Period agree Layout exposure events FD JSC CROCUS, compiled in compliance with fire safety requirements:

- Free access to cabinets fire hydrants; compliance width aisles exhibition stands (expositions), around the stage, (podium);
- Providing direct free passes to the door of the emergency exits;
- The use of fire-breaks with a minimum width of 8 m at the exhibition area of over 8,000 square meters.

13. Organizations – developers exhibition stands (expositions), stage boxes, podiums, stands , etc. , all project documentation for building , equipment, and design of exhibition stands (expositions), exhibits at the exhibition areas not later than 14 (fourteen) calendar days prior to the Overall event Period agree with the FD JSC CROCUS, which provide to the Engineering Department of General Builder in Crocus Expo IEC:

- Letters on the import of materials and equipment;
- Plan of the Exhibition event specifying the size and tied up with a specific booth (exposure) , main and emergency exits , the width of the main passage ;
- Floor plan of the exhibition booth (exposure) in an isometric view;
- Fire safety certificates (the conclusion of the test fire laboratory, a declaration of compliance) used for the construction and decoration of stands (floor, walls, ceiling) building and other materials, decorations, drapes, banners, equipment, etc.;
- Act on the flame-retardant treatment of combustible materials, decorations, drapery used for the design of exhibition stands (expositions), stage boxes, podiums, etc., as well as a copy of the license SFE (State Fire Emergency) ESM (Emergency Situations Ministry) of Russia providing fire-retardant treatment, and fire safety certificate for they applied flame retardants;
- A copy of the order appointing the officials responsible for fire safety in the construction of exhibition stands (exposure), and certificates confirming the passage of fire training program and technical minimum.

14. All building materials, decorations, drapes , wall , etc., used for the construction and design of the exposition in, must be certified in accordance with the law of the Russian Federation "On certification of products and services" from June 10, 1993 No. 5151-1 specially authorized executive authorities in the field of certification.

15. For construction and decoration of exhibition stands (expositions) are not permitted to use materials with higher fire hazard than:

- G2 (moderately), V2 (moderate), D3 (high smoke generation capacity), T3 (highly on the toxicity of combustion products) - finishing, wall hangings, ceiling and filling the ceilings (KM4);
- G2 (moderately), V2 (moderate), RP2 (poor extend (flame)), D3 (high smoke generation capacity), T2 (moderate toxicity of combustion products) - for floor coverings (KM3).

Fuels with higher fire hazard should be treated with flame retardants or other compensation provided for implementation of fire management activities consistent with the FD JSC CROCUS.

Suspended ceiling frames should be made of non-combustible materials.

Carpets, rugs and mats are to be fastened to the floor around the perimeter and at the joints.

16. Stands should be made of the elements of a high degree of readiness of pre-assembled and painted on the premises of the organization - builder.

On multilevel stands device spiral staircases, ladders fully or partially curved in plan, as well as winder and curved steps, steps with different tread width and different heights within the march stairs and stairwell are not allowed.

17. Mounting and installation of exhibitions and displays, information desks, decorations, different equipment should be carried out so as to avoid cluttering the evacuation passages and exits of the rooms, lobby, hallways, doors, office, storage and technical facilities as well as provide easy access

to controls (cabinets fire hydrants, fire fighting facilities, switchboards, cabinets, emergency stairs) located on the supporting columns and along the walls of the exhibition halls.

The specific location allowed for placement of external and internal displays, billboards, information desks, agreed with the Department of advertising and information of Crocus Expo IEC and FD JSC CROCUS.

To ensure free approach (not less than 0.8 m) to wardrobes fire hydrants, fire fighting facilities and switchboards allowed easy-open device designs (blinds, accordion doors, panels on magnets, etc.).

The width of aisles exhibition stands (expositions), around the stage, (podium) should be at least 3 m.

To the doors of emergency exits must be provided direct free passes to the width of doorways, but not less than 1.5 m of exhibition halls and 0.8 m - office, storage and technical rooms.

18. When installing temporary structures (tents, booths, tents, pavilions, etc.) in open areas (sites), as well as multi-storey stands and stands with closed volumes, ceiling slabs in pavilions must be equipped with wireless smoke detectors or additional automatic fire alarms connected to the control and indicating equipment fire alarm in the control room FD JSC CROCUS. Installation of detectors and alarms is carried by the General Builder in Crocus Expo IEC.

19. In the exhibition halls, exhibition halls, markets and exhibitions are prohibited:

- Smoking and naked flames;
- Install equipment and use materials not provided project documentation;
- Apply the finishing, upholstery materials of flammable plastics, polystyrene, polyvinyl chloride, vinyl leather, etc., that do not have fire safety certificates or test fire laboratory findings ;
- Warehouses of promotional materials and products, as well as workshops;
- Use territories showrooms (space) stands for the device places smoking and eating, dressing rooms, storage containers, packaging, exhibition designs, supplies and other materials;
- Use light diffusers organic glass, polystyrene and other combustible materials, and wrap electric lamps with paper, cloth, or other combustible materials, and operate lamps without caps (diffusers) provided lamp design;
- The use of non-standard (self-made) electric devices, electrical network-jerry buildings, sparking electric tools and wiring using splice joints;
- Completely off the light in the exhibition halls during exhibitions and other activities with the massive presence of people;
- To install additional power not provided the production technology;
- Left unattended included in equipment and devices;
- Use damaged sockets, switches, cables and wires, other faulty wiring products, as well as boilers and heaters with open heating elements or spirals;
- Installation of lighting fixtures, floodlights, spotlights and bulbs closer than 0.5 m from the exhibition equipment, stands, decorations, drapes, banners, sprinkler system;
- Use stationary circular saws, orbital sanders, not equipped with dust extraction;
- Store decorations, drapery, equipment and containers from under him, flammable materials under various scenes tablets, staircases and platforms, visually stands;
- Apply the paint on the basis of fuel, as well as aerosol cans of paint for painting (touch-up) stands and exhibits;
- Use and store HFL, C or containers with CG, empty gas cylinders, containers out of fuel and oil;
- Fill exhibition vehicles with fuel and discharge fuel to keep them open fuel tanks, as well as the presence of fuel or oil leakage;
- Recharge the batteries directly to the exhibition vehicles;
- Set in the halls the vehicles for transportation of flammable liquids and combustible, and CG;
- Use fire-extinguishing systems for pipelines suspension or mounting any equipment;
- Fastening elements stands, equipment and devices for pipelines of fire;
- Violate the integrity of fire sprinklers, smoke detectors;
- Use primary means of fire, internal fire hydrants installed on the sprinkler network for purposes other than fire fighting;
- Block (close) fire hydrants and approaches to them any equipment, stands, etc., as well as overlapping zones of fire detectors with banners, posters, decorations, curtains, aerostatic and air equipment (balloons, dirigibles, pneumatic, balloons and etc.) and other items.

20. In the exhibition and conference halls, spectator all installations and chairs should be connected in series with each other and firmly secured to the floor. When the number of seats a maximum of 200 seats mount to the floor may not be produced, but not necessarily in the ranks of their connection to each other.

21. For the exhibition and other events with a demonstration (demonstration, installation) of vehicles of more than 25 units of event organizer must be a plan of arrangement vehicle description strand sequence and evacuation in case of fire. Plan agreed with the FD JSC CROCUS.

Exhibition halls and outdoor areas, which demonstrates the vehicles must be equipped with tow lines or bars at the rate of one wire (Rod) 10 units of exhibition equipment. Venues demonstration runs ("test-drive") to be secured by the leased at Crocus Expo IEC primary means of fire, and if necessary, put up fire positions from among those FD JSC CROCUS.

Electrical connection in showrooms Crocus Expo IEC is made only by experts on the basis of maps of electric wiring made by General Builder in Crocus Expo IEC.

All portable wires and cables used to connect the lighting and other equipment in the exhibition halls to be laid in such a way as to prevent any damage.

Wires and lighting cables laid on the floor where people pass and carrying of goods must be protected crossovers.

Plugged into sockets portable lights and electric appliances may only during their use.

22. When placing the exhibition stands (expositions), pavilions, tents, tents, etc. in open areas (sites) organizers must rent in Crocus Expo IEC primary means of fire (portable, mobile, extinguisher, automatic fire extinguishers) in the amount of certain applications number 1 and number 2 of the Rules of fire safety conditions in the Russian Federation and to the nomination of the movable fire post of the number of specialists FD JSC CROCUS.

Use of open fire (torches, candles, chandeliers, etc.), as well as to demonstrate exhibits with open fire, production shots, fireworks, fire show, fireworks and other special effects smoke allowed in exceptional cases, with the written permission of the FD JSC CROCUS and fielding individual fire post. Imitation shots and explosions carried out by means of special devices ensuring absolute fire safety.

23. To obtain permission to conduct fireworks, fire shows and other special pyrotechnic effects their organizers must submit FD JSC CROCUS a written statement within a period not less than five (5) days before the scheduled date of the event. By written request must be accompanied by:

– An order appointing a person responsible for compliance with fire safety measures during the event;

– Layout of pyrotechnic units, binding scheme storage facilities and installation of fireworks, pyrotechnics to the terrain and the distance to the buildings, the scheme cordon venue fireworks showing the boundaries of the danger zone.

Conducting fire shows and other special pyrotechnic effects must be organized in accordance with the requirements of the "Instructions on fire safety measures in the organization and apparatus fireworks, fire shows and other special pyrotechnic effects on the territory of JSC CROCUS". After the event it is necessary to make a thorough check of the special effect away smoldering material residues and unburned parts of fireworks and air the room using the ventilation systems.

24. For all types of fire and other fire hazard in the field exposures (stand) areas should be formalized in the FD JSC CROCUS work permit, signed by the Deputy Chief Engineer of Crocus Expo IEC and the contractor must pass fire drill.

The exception may be only emergency works that are permit and approval in place.

25. In order to prevent hot metal particles and sparks in adjacent expositions floors under all equipment and installation inspection, technological and other hatches, ventilation, installation and other openings (holes) in ceilings, walls and partitions space where hot work covered with noncombustible materials or fire cloth and, if necessary, watered .

Place hot work should be checked staff FD JSC CROCUS, cleared of combustible substances and materials, provided the primary means of fire (fire extinguisher, sand box and a shovel, a bucket of water, fire protection cloth, etc.).

The contractor shall ensure thorough check of hot work operation for 3 hours after.

26. Demonstration of units and units using flammable liquids and combustible, shall be permitted only upon supplying pipeline from a tank located outdoors and not closer than 10 m from them,

and the exhaust gases out. Use of cylinders with combustible (CG) and toxic (TG) gases as well as storage of empty bottles at the stands inside buildings pavilions are not allowed. Allowed to use cylinders with inert gases (IG), but only if their immediate removal after use outside the pavilion. Accommodation group balloon installations for supplying gas to the place of cutting and welding demonstration work is allowed outside the building of the pavilion at the "deaf" (without openings) exterior walls.

Feed gas from the balloon group settings to a place at the booth demonstrations are allowed on high pressure hose length should not exceed 30 m, and which should be covered with protective ramps (bridges).

Gas cylinders must be stored in special structures in open areas no closer than 10 m to the buildings. Special facilities should protect cylinders against rain; sunlight and other heat sources, have natural ventilation and be made of non-combustible materials.

In places of storage of gas cylinders shall be posted notices (posters) security ("The passage is closed", "No Smoking", "Do not run from the fire", etc.).

Cylinders with CG must be stored separately (in different warehouses or at different sites) with oxygen from the cylinder, compressed air, chlorine, fluorine and other oxidants, and cylinders of TG. During storage and transportation of oxygen cylinders should not be allowed to oils (fats) and ground reinforcement cylinder oiled materials. When you change edges of oxygen cylinders manually is not allowed to take up the valves. Valves stored cylinders shall be closed with safety valves. Cylinders with gases having "boots", should be stored upright in a special jacks, crates or other devices that exclude them from falling. Containers which do not have "boots" should be stored horizontally on racks or shelves of non-combustible materials. Stack height should not exceed 1.5 m, and the valves should be turned to one side.

Upon detection of gas leakage from the cylinders, they must be removed from the special facilities in a safe place.

Storage of any other substances, materials and equipment in storage of gas cylinders are not allowed.

When dealing with empty gas cylinders must be respected the same security measures as well as with the filled bottles.

Storage location of gas cylinders and demonstration of cutting and welding works should be provided with fire. At the event, all extinguishing agents are rented by Crocus Expo IEC.

At the booth should contain the following documents:

- Certificates of compliance and fire safety in welding and cutting equipment;
- A copy of the order appointing the responsible official for fire safety and a certificate of passing them training program fire-technical minimum.
- Welder Certificate;
- Work permit to perform hazardous work;
- Inspection certificate gas cylinders.

Fire safety measures and requirements for workplace defined by the "Instruction on fire safety during welding demonstration in pavilions Crocus Expo IEC".

IV. PROCEDURE RULES FOR FIRE DEVELOPMENT

27. Each employee, contractor, participant of exhibitions fire detection (fire) or signs of combustion (smoke, burning smell, fever, etc.) must:

27.1. Report all persons present on the stand, in the detection of indoor fire (ignition).

27.2. Immediately inform the FD JSC CROCUS via phone **35-01, (495) 727-11-37, (916) 547-03-78** or on duty security officer administrator hall or any other administration officials pavilions Crocus Expo IEC.

It is necessary to specify the exact location of the fire (stand number and name, the room floor) that on fire, your name and phone number from which the message is transmitted.

27.3. Take measures to evacuate people from the territory of the exhibition booth (exposure) from the exhibition hall.

27.4. Start fire fighting primary means fire.

28. Managers and officials responsible for fire safety in places of expositions and stands arrived at the scene of the fire shall:

28.1. Duplicate message about fire (ignition) in the FD JSC CROCUS, put the on-duty shift supervisor of information and analytical center of security service of JSC CROCUS (phone 55-55, (495) 980-11-11), exhibition management and top management.

28.2. In case of threat to human life immediately organize rescue using the means and resources available. Remove from the danger zone for all employees and visitors who are not involved in extinguishing the fire (ignition).

28.3. Organize, together with the fire extinguishing, evacuation and protection of wealth.

28.4. Upon arrival, fighting crew of FD JSC CROCUS, supernumerary fire brigade Crocus Expo IEC, the fire fighting crew compartment JSC CROCUS or fire of territorial bodies of the Russian Emergencies Ministry to inform them about the situation, design and technological specifications of the stand space and other necessary information.

Appendix 1:

The penalty for violation of “Basic requirements while hosting events in Crocus Expo IEC”

Appendix 1: The penalty for violation of “Basic requirements while hosting events in Crocus Expo IEC”

№ in sequence	Violation	The clause of general requirements	Penalty	Notice
1.	The import on the territory of the exhibition hall, installation and use of equipment and materials that not covered by the project documentation without fire safety certificates; use of combustible materials not treated with flame retardant for exhibition stands (expositions).	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	25.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder.
2.	The installation and maintenance of electrical equipment with the violations Electrical Installations Code, the maintenance of electric consumers; the use of non-standard (self-made), damaged electric appliances of electrical fittings; placing the tissue, paper and other combustible materials on lighting fixtures; the placement of lighting equipment closer than 0.5 m from combustible materials, displays, decorations and sprinkler fire-extinguishing system.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	25.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder.
3.	The reducing of the walkways width, the blocking of escape routes, main and emergency exits, approaches to technical facilities, fire breaks between the walls of buildings and stands, exhibitions, shelves, approaches to fire alarm media, fire hydrant cabinets, fire extinguishers, electrical boards and other technological equipment by various goods, equipment, property, containers, packaging and	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	20.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder.

	other devices to prevent evacuation.			
4.	Storage of goods, property, building materials, containers, packaging and other material with the violation of the distances to the walls of buildings and fire hydrants under passage galleries. The blocking of approach to fire hydrants, gas and diesel generators, transformer substations, as well as installation of containers, pallets, crates and vehicles on fire hydrant manhole covers.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	10.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder.
5.	Smoking in the workplace, on the territory of the exhibition hall, stand, exhibition, in the administrative, production, technical, or warehouse premise, in other places not designated for such purposes.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	10.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.
6.	The conduct of fire and other fire hazard works without issuing the permit, coordination with the Technical Maintenance Service of the "Crocus Expo" and the division of the Fire protection administration of JSC CROCUS and with the violation of fire safety rules.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	20.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.
7.	The use of sparking tool, open fire, demonstration of exhibits/ products using open source flame, fireworks, fire shows, pyrotechnic special effects in buildings, structures, pavilions without the coordination of the Fire protection administration of JSC CROCUS.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and	25.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.

		Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»		
8.	The use and storage of flammable and combustible liquids and gases, filling the vehicles with fuel and it's unloading; keeping a vehicle with an open neck of the fuel tank, as well as the presence of fuel or oil leakage.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	20.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.
9.	The violations of fire safety regulations that caused the fire (lighting up), causing damage to the property of JSC CROCUS.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	1.000.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.
10.	The violations of fire safety regulations that caused the lighting up, not causing damage to the property of JSC CROCUS.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	The amount of the penalty set in clauses 2-9 of the present Appendix shall be increased by 100%	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder.
11.	The damage to the manual alarm call point of the automatic fire alarm system, bringing it into effect without any signs of fire.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the	20.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.

		Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»		
12.	The damage to the fire cock cabinets, fire extinguishers. Misuse of fire hydrants, fire hoses, fire extinguishers and equipment, their loss, fixing of the equipment and the property to the pipelines of the fire-fighting system.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	20.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with representatives of General Builder. The damage done is paid additionally.
13.	The damage to the sprinklers of the automatic sprinkler fire-extinguishing system.	The Federal Law №120-FZ dated 03.06.2011 and Order by the Director of Krasnogorsk subsidiary of Crocus Expo JSC CROCUS No.01-02/28P dated 23.04.2015 «On the Procedure for Ensuring the Fire Safety within the Territory, in Buildings, Structures and Premises of the Facilities of Crocus Expo Krasnogorsk subsidiary JSC CROCUS»	30.000 Roubles	The penalty is imposed by the authorized representatives of the JSC CROCUS Fire protection administration together with Representatives of General Builder. The damage done is paid additionally.